

Reducing Tee (P X FPT)	P x P x FPT
	Job Name <input type="text"/> Job Location <input type="text"/> P.O.# <input type="text"/> Engineer <input type="text"/> Contractor <input type="text"/> Wholesaler <input type="text"/> Merit Associate <input type="text"/>

CopperPress® Small Diameter Reducing Tee P x P x FPT is available in sizes ½" x ½" FPT – 2" x ¾" FPT with an EPDM sealing element.

- **FIRST TO MARKET Visual Indicator Press Ring® (VIPR®)** - facilitates immediate identification of un-pressed connections.
- **Leak Before Press (LBP)** - in addition to the VIPR®, all sizes have leak before press technology, which guarantees a visual indication if the fitting is not pressed.
- **Applications:** HVAC, plumbing, municipal, mechanical and industrial applications.

Reducing Tee (P x FPT)				P x P x FPT		
Item Number	D1 (in)	D2 (in)	L1 (in)	A1 (in)	L2 (in)	A2 (in)
EPDM						
MB40000	½"	½" FPT	1.56	0.75	1.44	0.89
MB40010	¾"	¼" FPT	1.63	0.69	1.34	0.93
MB40020	¾"	½" FPT	1.79	0.85	1.38	0.83
MB40030	¾"	¾" FPT	1.79	0.85	1.61	0.98
MB40040	1"	½" FPT	1.63	0.69	1.71	1.16
MB40050	1"	¾" FPT	1.91	0.96	1.85	1.22
MB40060	1¼"	½" FPT	1.87	0.73	1.67	1.12
MB40070	1¼"	¾" FPT	1.99	0.85	1.81	1.18
MB40080	1½"	½" FPT	2.13	0.67	1.83	1.28
MB40100	1½"	¾" FPT	2.26	0.81	1.97	1.34
MB40110	2"	½" FPT	2.54	0.93	2.09	1.54
MB40120	2"	¾" FPT	2.54	0.93	2.30	1.67

CopperPress® Operational Parameters:

EPDM working pressure range from full vacuum to 300 psi for water.

CopperPress® Fitting Certifications

ICC-ES LC1002, NSF/ANSI/CAN 61, NSF/ANSI/CAN 372, IAPMO Z 1117.

CopperPress® Codes and Standards

ASME B31.1, B31.3, B31.9, IPC, IMC, IRC, UPC, UMC, CPC & CMC, City of Los Angeles Plumbing and Mechanical Codes, Massachusetts Regulation 248 CMR 10.00: Uniform State Plumbing Code, Massachusetts State Building Code 780 CMR Ninth Edition: Chapter 28.

